



Certificate of Compliance

Certificate: 70016504

Master Contract: 151230

Project: 70016504

Date Issued: April 17, 2015

Issued to: Enovation Controls, LLC

P.O. Box 470248

Tulsa, OK 74147

USA

Attention: Justin Nguyen

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Wei Shi

Issued by: Wei Shi

PRODUCTS

CLASS 2252 86 - PROCESS CONTROL EQUIPMENT - Certified to US Standards

CLASS 2252 06 - PROCESS CONTROL EQUIPMENT

Component Engine Monitoring System Controller, Model MPC-20 and CXM-110, rated 8-32Vdc, 146W max

Notes:

1. The above models are Pollution Degree 2, Installation Category 2.
2. Mode of operation: Continuous
3. Environmental Conditions: Extended: -40° to 85° C
4. Not evaluated to mechanical and fire enclosure requirements, to be determined in the end use.
5. Investigated for Basic Insulation only, second level of protection to be determined in end use.
6. If at any time there is a conflict between the system safety provision and any relevant local (national or Regional) requirements, the local requirements always take precedence.
7. Equipment is not to be used with or near flammable liquids.



Certificate: 70016504

Master Contract: 151230

Project: 70016504

Date Issued: April 17, 2015

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 61010-1-12 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements

UL Std. No. 61010-1 (3rd Edition) - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements



Supplement to Certificate of Compliance

Certificate: 70016504

Master Contract: 151230

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
70016504	Apr 17, 2015	CSA C-US report #2682206 upgrade from 61010 2nd Ed. to 3rd Ed. and to include alternate construction and typo corrections.