



Certificate of Compliance

Certificate: 70026867

Master Contract: 151230

Project: 70026867

Date Issued: September 10, 2015

Issued to: Enovation Controls, LLC

P.O. Box 470248

Tulsa, OK 74147

USA

Attention: Alan Rosenbaum

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Wei Shi

Issued by: Wei Shi

PRODUCTS

CLASS 2252 86 - PROCESS CONTROL EQUIPMENT - Certified to US Standards

CLASS 2252 06 - PROCESS CONTROL EQUIPMENT

Engine Monitoring System Controller, Model MPC-10, rated 8-32Vdc, 100W max

Notes:

The above equipment is Pollution Degree 2, Installation Category 2.

Condition of acceptability:

- The equipment is intended to be powered by vehicle battery or Safety Extra Low Voltage DC sources
- The equipment Operation mode: Continuous.
- Environmental condition: -40°C to 85°C
- Not evaluated to mechanical and fire enclosure requirements, to be determined at end installation.
- If at any time there is a conflict between the system safety and provisions and relevant local (national or regional) requirements, the local requirements always take precedence
- The Equipment is not to be used with or near flammable liquids.



Certificate: 70026867

Master Contract: 151230

Project: 70026867

Date Issued: September 10, 2015

APPLICABLE REQUIREMENTS

CSA Standards:

CAN/CSA-C22.2 No. 61010-1-12 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements

UL Standards:

UL Std. No. 61010-1 (3rd Edition) - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements