



Certificate of Compliance

Certificate: 2385613

Master Contract: 151230

Project: 2385613

Date Issued: March 3, 2011

Issued to: FW Murphy

P.O. Box 470248
Tulsa, OK 74147
USA

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Vincent Dang

Issued by: Vincent Dang, P.Eng.

PRODUCTS

CLASS 2252 05 - PROCESS CONTROL EQUIPMENT

CLASS 2252 85 - PROCESS CONTROL EQUIPMENT - Certified to US Standards

Engine Monitoring System Controller, Model EMS PRO, cord connected, rated 9 - 29 V dc, 3.5 A max.; Relay rated 5 A max.

Notes:

The above model is Equipment Class 2, Pollution Degree 2, Installation Category II.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 61010-1-04 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements

UL Std. No. 61010-1 (2nd Edition) - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements

UL Std. No. 1977 - Connectors (Use as a Guide)



Supplement to Certificate of Compliance

Certificate: 2385613

Master Contract: 151230

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
2385613	March 3, 2011	Engine Monitoring System Controller, Model EMS PRO. (C/US)